



**DALLAS COUNTY  
PURCHASING DEPARTMENT**  
900 Jackson Street,  
Founders Square, Suite 680  
Dallas, Texas 75202

May 10, 2018

**GENERAL INFORMATION NO. 3**

**Solicitation # 2018-025-6718**

**Invitation for Bid George Allen Building Underground Storage Tank Replacement**

*THIS DOCUMENT IS BEING PROVIDED FOR GENERAL INFORMATION PURPOSES  
ONLY (THIS IS NOT AN ADDENDUM)*

The Dallas County Purchasing Department has received and hereby provides for general information purposes only the following questions and the County's responses. (Note: Due to time constraints, Dallas County will not be responsible for ensuring confirmation vendor receipt of this and/or any further acceptance of and/or responses to future questions prior to the solicitation opening date.)

**Question No. 1:** The specs indicate providing a new transfer and return pump but during the walk through it was indicated that we would tie into the old system with the new piping please clarify?

**Response:** *Pumps for the new day tank (DT-1) shall be new as specified. Refer to drawings for piping that will be re-used.*

**Question No. 2:** During the site visit / pre bid conference it was said that we were to provide a temporary day tank until the new fuel tank was installed. In the specs it is noted that we are to provide a new day tank. Would you please clarify because we thought the scope of work was only tying in to the existing day tanks?

**Response:** *There is one day tank that is being replaced, DT-1. Refer to P0.1 for schedule and P2.1 to see location of new day tank.*